

From Director General
Fire Service, Haryana Panchkula

To **M/s SIRSA EDUCATION SOCIETY**
SES PARISAR B BLOCK NEAR DURGA MANDIR SIRSA HARYANA

Memo No. FS/2023/704 dated : 03/08/2023

Subject : **Fire Safety Certificate 15 mtrs. and Above from the fire safety point of view for Group B- Educational Building at SES PARISAR B BLOCK NEAR DURGA MANDIR SIRSA HARYANA of SIRSA EDUCATION SOCIETY :**

Reference your letter no. 171022323000133 dated 05/07/2023 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Coverage
C M K NATIONAL P G COLLEGE BLOCK 1	GROUND + 01 FLOOR	8.22 MTRS	3226.76 SQM
C M K NATIONAL P G COLLEGE BLOCK 2	GROUND + 02 FLOOR	12.80 MTRS	934.20 SQM
C M K NATIONAL P G COLLEGE HOSTEL PART 1 AND 2	GROUND + 02 FLOOR	12.59 MTRS	1590.93 SQM
G R G NATIONAL GIRLS SENIOR SECONDARY SCHOOL HOSTE	GROUND FLOOR ONLY	4.19 MTRS	1115.89 SQM
NATIONAL COLLEGE OF EDUCATION	GROUND + 02 FLOOR	11.65 MTRS	1133.33 SQM
CANTEEN BLOCK	GROUND + 01 FLOOR	8.22 MTRS	325.64 SQM
G R G NATIONAL GIRLS SENIOR SECONDARY SCHOOL	GROUND + 02 FLOOR	11.81 MTRS	2423.31 SQM
LALA SOMNATH GANDA AUDITORIUM	GROUND + 01 FLOOR	6.4 MTRS	1004.24 SQM
LALA HANSRAJ PHUTELA COLLEGE OF LAW	GROUND + 03 FLOOR	16 MTRS	1019.59 SQM
PRINCIPAL RESIDENCE	GROUND FLOOR ONLY	4.19 MTRS	248.64 SQM
Tower Name	Basement Level	Basement Area	Basement Remarks
NIL	NIL	NIL	NIL

- 1) The owner/occupier shall give a self declaration certificate annually regarding fire safety system installed in his building/premises is working in good condition and there is no addition/alteration in the building.
- 2) In case there is any addition/alteration in the building, the Fire Safety Certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme
- 3) As per sub-section (1) and the competent authority may randomly check such building/premises.
- 4) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 5) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 6) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per rules against you.
- 7) You are directed to apply for Fire Safety Certificate in future before 2 months of expiry of your Fire Safety Certificate.
- 8) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 9) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Section 30,31 & 47 of Fire & Emergency Services Act 2022.
- 10) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Official/Staff should be participated in the drill.
- 11) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 12) Fire safety Certificate granted subject to condition that there is no violation in sanctioned building plan by virtue of which fire fighting scheme was approved.
- 13) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire fighting system installed in his building is working in good condition and there is no addition/alteration in the building. The Fire Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under the Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approval of revised Fire Fighting Scheme as per the provisions of section 18.

The above Fire Safety Certificate is valid for only **Three** year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.



Deputy Director (Technical)-I,
for Director General, Fire
Service, Haryana

Panchkula

Exercising the power of Director, Fire Services, Haryana